

2009 Annual Drinking Water Quality Report

(Consumer Confidence Report)

CITY OF DUNCANVILLE

Phone Number: 972-780-4900

SPECIAL NOTICE

Required language for ALL community public water supplies:

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly or immunocompromised persons such as those undergoing chemotherapy for cancer, those who have undergone organ transplants, those who are undergoing treatment with steroids, and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline at (800) 426-4791.

Public Participation Opportunities

Duncanville Water Utilities is a non-profit department of the City of Duncanville and is governed by the Duncanville City Council. The City Council meets every first and third Tuesday. For more information on meetings or how to register as a speaker, contact the City Secretary's office at (972) 780-5017.

Following are other helpful telephone numbers:

- Questions or concerns about water quality (972) 780-4900
- Questions about your bill (972) 780-5010
- For brochures on water conservation (972) 780-4900

To learn about future public meetings (concerning your drinking water) or to request a meeting to be scheduled, please contact us.

Our Drinking Water Meets or Exceeds All Federal (EPA) Drinking Water Requirements

This report is a summary of the quality of the water we provide our customers. This analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. We hope this information helps you become more knowledgeable about what is in your drinking water.

WATER SOURCES: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water before treatment include: microbes, inorganic contaminants, pesticides, herbicides, radioactive contaminants, and organic chemical contaminants.

En Español

Este informe incluye información importante sobre el agua potable. Si tiene preguntas o comentarios sobre éste informe en español, favor de llamar al tel. (972)780 -4900 - para hablar con una persona bilingüe en español.

Where do we get our drinking water?

Our drinking water is obtained from SURFACE water sources. It comes from the following Lake/River/Reservoir/Aquifer: LAKE TAWAKONI, LAKE RAY HUBBARD, ELM FORK TRINITY RIVER. A Source Water Susceptibility Assessment for your drinking water source (s) is currently being updated by the Texas Commission on Environmental Quality. This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment allows us to focus our source water protection strategies. Some of this source water assessment information will be available later this year at Texas Drinking Water Watch (<http://dww.tceq.state.tx.us/DWW/>) . For more information on source water assessments and protection efforts for our system, please contact us

ALL drinking water may contain contaminants.

When drinking water meets federal standards, there may not be any health-based benefits to purchasing bottled water or point of use devices. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

Secondary Constituents

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concern. Therefore, secondaries are not required to be reported in this document, but they may greatly affect the appearance and taste of your water.

About The Following Pages

The pages that follow list all the federally regulated or monitored contaminants which have been found in your drinking water. The U.S. EPA requires water systems to test for up to 97 contaminants.

DEFINITIONS

Maximum Contaminant Level (MCL)

The highest permissible level of a contaminant in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG)

The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL)

The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG)

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Treatment Technique (TT)

A required process intended to reduce the level of a contaminant in drinking water.

Action Level (AL)

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

ABBREVIATIONS

- NTU** - Nephelometric Turbidity Units
- MFL** - million fibers per liter (a measure of asbestos)
- pCi/L** - picocuries per liter (a measure of radioactivity)
- ppm** - parts per million, or milligrams per liter (mg/L)
- ppb** - parts per billion, or micrograms per liter (µg/L)
- ppt** - parts per trillion, or nanograms per liter
- ppq** - parts per quadrillion, or picograms per liter

Inorganic Contaminants

Year or Range	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	MCLG	Unit of Measure	Source of Contaminant
2009	Fluoride	0.7	0.34	0.87	4	4	ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
2009	Nitrate as (N)	0.21	<0.02	0.79	10	10	ppm	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
2009	Bromate	<0.50	<5.0	5.7	10.0	0.0	ppb	By-product of drinking water disinfection
2006	Gross beta emitters	5.4	4.4	6.4	50	0	pCi/L	Decay of natural and man-made deposits.
2009	Barium	0.021	0.014	0.033	2	2	ppm	Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits.

Organic Contaminants

Year or Range	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	MCLG	Unit of Measure	Source of Contaminant
2009	Lindane	0.14	0.14	0.14	0.2	0.2	ppb	Runoff/leaching from insecticide used on cattle, lumber, gardens.
2009	Simazine	0.15	0.10	0.23	4	4	ppb	Herbicide runoff.
2009	Atrazine	0.34	0.23	0.48	3	3	ppb	Runoff from herbicide used on row crops.

Maximum Residual Disinfectant Level

Year	Disinfectant	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit of Measure	Source of Disinfectant
2009	Chloramine Residual	1.3	.5	3.6	4	4	ppm	Disinfectant used to control microbes.

Disinfection Byproducts

Year	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	Unit of Measure	Source of Contaminant
2009	Total Haloacetic Acids	16.2	10.3	26.7	60	ppb	Byproduct of drinking water disinfection.
2009	Total Trihalomethanes	32.7	14.9	58.9	80	ppb	Byproduct of drinking water disinfection.

Unregulated Initial Distribution System Evaluation for Disinfection Byproducts

This evaluation is sampling required by EPA to determine the range of total trihalomethane and haloacetic acid in the system for future regulations. The samples are not used for compliance and may have been collected under non-standard conditions. EPA also requires the data to be reported here.

Year	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	Unit of Measure	Source of Contaminant
2007	Total Haloacetic Acids	15.3	0	58.6	NA	ppb	Byproduct of drinking water disinfection.
2007	Total Trihalomethanes	61.5	21.1	156.2	NA	ppb	Byproduct of drinking water disinfection.

Unregulated Contaminants

Bromoform, chloroform, dichlorobromomethane, and dibromochloromethane are disinfection byproducts. There is no maximum contaminant level for these chemicals at the entry point to distribution.

Year or Range	Contaminant	Average Level	Minimum Level	Maximum Level	Unit of Measure	Source of Contaminant
2009	Bromoform	.45	<0.1	<0.1	ppb	Byproduct of drinking water disinfection.
2009	Chloroform	28.6	10.2	55.3	ppb	Byproduct of drinking water disinfection.
2009	Bromodichloromethane	3.5	2.6	4.2	ppb	Byproduct of drinking water disinfection.
2009	Dibromochloromethane	.80	<0.1	2.12	ppb	Byproduct of drinking water disinfection.

Lead and Copper

Year	Contaminant	The 90th Percentile	Number of Sites Exceeding Action Level	Action Level	Unit of Measure	Source of Contaminant
2007	Lead	8.3	1	15	ppb	Corrosion of household plumbing systems; erosion of natural deposits.
2007	Copper	0.591	0	1.3	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.

Required Additional Health Information for Lead

"If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>."

Turbidity

Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

Year	Contaminant	Highest Single Measurement	Lowest Monthly % of Samples Meeting Limits	Turbidity Limits	Unit of Measure	Source of Contaminant
2009	Turbidity	0.10	100.00	0.3	NTU	Soil runoff.

Total Coliform

Total coliform bacteria are used as indicators of microbial contamination of drinking water because testing for them is easy. While not disease-causing organisms themselves, they are often found in association with other microbes that are capable of causing disease. Coliform bacteria are more hardy than many disease-causing organisms; therefore, their absence from water is a good indication that the water is microbiologically safe for human consumption.

Year	Contaminant	Highest Monthly % of Positive Samples	MCL	Unit of Measure	Source of Contaminant
2009	Total Coliform Bacteria	2.2%	*	Presence	Naturally present in the environment.

*** Presence of coliform bacteria in 5% or more of the monthly samples.**

Fecal Coliform

Reported monthly tests found no fecal coliform bacteria.

Secondary and Other Constituents Not Regulated

(No associated adverse health effects)

Year or Range	Constituent	Average Level	Minimum Level	Maximum Level	Secondary Limit	Unit of Measure	Source of Constituent
2009	Bicarbonate	41	12	92	NA	ppm	Corrosion of carbonate rocks such as limestone.
2009	Chloride	33	14	47	300	ppm	Abundant naturally occurring element; used in water purification; byproduct of oil field activity
2009	Hardness as Ca/Co3	93	36	128	NA	ppm	Naturally occurring calcium and magnesium.
2009	pH	8.8	7.9	9.4	>7.0	units	Measure of corrosivity of water.
2009	Sodium	29	9	61	NA	ppm	Erosion of natural deposits; byproduct of oil field activity.
2009	Sulfate	65	39	116	300	ppm	Naturally occurring; common industrial byproduct; byproduct of oil field activity.
2009	Total Alkalinity as CaCO3	46	30	100	NA	ppm	Naturally occurring soluble mineral salts.
2009	Total Dissolved Solids	217	120	333	1000	ppm	Total dissolved mineral constituents in water.