

CAMPBELL ENGINEERING, INC.

*James A. Campbell, President*

112 SOUTH MADISON AVE. ★ TELEPHONE 942-1671

DALLAS, TEXAS 75208

December 21, 1981

Mr. Norman Wuerch  
826 Glen Oaks Blvd.  
Dallas, Texas 75232

927 GREEN TREE LANE

Dear Mr. Wuerch:

The existing foundation at 927 Green Tree Lane, Lot 4, Block B, Sixth Section Greenway Estates, an addition to the City of Duncanville, Texas, has been checked and found to be at an elevation of 658.86 ft.

The one hundred year flood elevation as shown on the flood insurance study for the City of Duncanville, Texas, published by the Federal Insurance Administration, dated on April 28, 1981, is 656.0 ft. This requires a minimum floor elevation of 658.0 ft. The foundation is higher than this.

Very truly yours,

*James A. Campbell*

JAMES A. CAMPBELL, P.E.

