

*File*

CAMPBELL ENGINEERING, INC.

*James A. Campbell, President*

112 SOUTH MADISON AVE. ★ TELEPHONE 942-1671

DALLAS, TEXAS 75208

July 25, 1981

1518 GREEN TREE LN

TO WHOM IT MAY CONCERN:

Lot 15, Block A, First Section Greenbriar Estates, an addition to the City of Duncanville, Texas, has been checked and found to be at an elevation of 667.8 ft. in the middle of the lot 75 ft. southeast of Green Tree Lane. The 100 year flood elevation as determined by the U.S. Army Corp of Engineers, May 1981, is 661.2 ft. which requires a minimum floor elevation of 676.2 ft.

The file plat shows a minimum floor elevation of 663.5 ft. The floor elevation of the proposed residence should be approximately 668.5 ft.

*James A. Campbell*  
JAMES A. CAMPBELL, P.E.